

Demand response planning in capacity market using microgrid

Mohammad Khadem¹, Mahdi Karami²

¹Department of Electrical Engineering, Khormuj Branch, Islamic Azad University, Khormuj, Iran

²Department of Electrical Engineering, Jam Branch, Islamic Azad University, Jam, Iran

Article Info

Article history:

Received Apr 12, 2021

Revised Dec 24, 2021

Accepted Jan 2, 2022

Keywords:

Capacity market

Demand response

Development cost

Microgrid

Transmission system

ABSTRACT

Planning of the demand response has received special attention due to the cost of transmission lines development and shortage of energy resources beside the growth of demand. This research work is focused on the role of microgrid (MG) as an alternative solution for transmission system development and proposed a method for modeling of MGs in the capacity market. The results show that using of MGs leads to reduce the development costs of transmission system. Moreover, MGs cause a slight increase in the profitability of selling capacity to the consumers. These outcomes prove that continuing to grow the number and capacity of MGs in each area ultimately eliminate the inquiry of transmission network development and minimize the cost of capacity market.

This is an open access article under the [CC BY-SA](https://creativecommons.org/licenses/by-sa/4.0/) license.



Corresponding Author:

Mohammad Khadem

Department of Electrical Engineering, Khormuj Branch, Islamic Azad University

Lavar Sharghi Road, Khormuj 7541668395, Bushehr Province, Iran

Email: mohammad.khadem8739@yahoo.com

1. INTRODUCTION

Environmental considerations such as pollutions, greenhouse gases and landfills are the major issues in recent years [1]–[3] which has attracted a lot of attention for efficiency improvement of power systems and electrical machines [4], [5]. Development of the transmission system is a significant factor in power network design that determine the optimal configuration for a system based on load demand and increases network reliability. In fact, the expansion of transmission lines is not always cost-effective and other solutions need to be considered. The load response programs have been considered for several reasons such as reducing the peak, preventing the rapid price changing in the electricity market, and increasing the efficiency of the power system and the energy market. Planning for system development was started in 1970 with the aim of minimizing development costs and considering power generation constraints and line capacity using the linear planning method. Different techniques have been used in network development planning such as sensitivity analysis algorithm, ant colony algorithm, genetic algorithm, and Tabu search [6]–[12]. Electric industry has undergone fundamental changes around the world in the last two decades which are referred to various headings such as restructuring [13], [14]. Demand response can be applied for source of power supply and improve the system reliability. To solve the planning problem for transmission system development, the microgrids (MGs) will be the best solution to reduce the capacity of load demand instead of implementing the new costly transmission line. MGs consist of a set of the energy sources which are able to supply their local load by two modes as separate and grid-connected. MGs can interact with each other as well as with distribution companies. The interaction of MGs with the distribution company can take place in a local electricity market in which MGs can act as consumers or producers at any time according to their resources and consumption. MGs can also provide the amount of reservation requested by the distribution company in order to accompany with the upstream reservation market. Certainly, the simultaneous

interaction of MGs and distribution companies in the energy markets and local reserves will change their behavior and decision-making. On the other hand, MGs can interact with each other so that they use each other's resources to reduce the cost of the entire system. The interaction of MGs lead to the use of resources and reduce the dependency to the upstream system [15]. Planning of transmission lines development by MGs is not reported well as a solution for capacity market. One of the problems in development of power system is to determine the time, place, size, and optimal number of new elements to supply the demand [16]. The transmission expansion planning (TEP) problem can be expressed in terms of methods, constraints, and objective functions. It can also be studied from various aspects such as modeling and solution method [17]. The TEP problem is modeled on a pond-based electricity market [18]. In this model, a number of scenarios have been presented for future consumption demand, which will help to examine the issue of operation in planning. A three-level model is formulated for TEP, which is performed at the lowest level of market settlement, at the middle level of production capacity development, and at the highest level of transmission capacity development [19]. A dynamic capacity investment model is proposed in [20] to investigate the effect of various options in capacity market design within three frameworks. The outcomes are compared in electricity pricing policy, reliability, and sustainability. The effect of integrating distributed generation resources and MGs in the development and production of transmission systems is investigated [21]. An optimal method for integrating these resources transmission development planning is presented with the main purpose of cost minimization.

Independent operators of different systems around the world based on the consuming of load in the capacity market are divided into three categories. Some of them are the operators in California and United Kingdom which studied and designed an appropriate structure for capacity market to implement the programs of load response and energy efficiency. The mentioned operators believed that it is necessary to study further and use the experiences of the other markets in resource management. The second group of operators such as New York independent system operator (NYISO) and Midwest independent system operator (MISO) in the United States use consumption management programs to provide adequate resources but introduce a competitive structure to compete between subscribers [22]. The New York operator is forcing the resource providers to participate in times of shortage. These suppliers receive a monthly stipend in exchange for a commitment to participate when needed. The operator of Mideast region also uses these resources in two ways of providing capacity. The first method is to use emergency response programs to ensure resource adequacy. This operator pays a price equal to the highest bid from providers to all participants. The second method is to allow the distribution company to reduce the load of subscribers in order to commit to their monthly capacity [23]. The third category of operators such as New England and Pennsylvania-Jersey-Maryland (PJM) operators has three types of demand response (DR) products including the limited DR, extended summer DR and annual AD with the capacity to involve in the market [24]. This participation in the PJM capacity market has been introduced and modeled in [25].

This article examined the effectiveness of MGs as an alternative solution for development of transmission line in capacity market. An effective method is proposed for modeling of capacity market and demand response. The application of MG as a power supply source of capacity market is analyzed. The results show that the addition of MGs causes a significant reduction in the cost of transmission system development.

2. RESEARCH METHOD

Sellers and buyers have been existed in a capacity market to trade of the sources [26]. Normally, the purchaser are LSEs that supply the needs of their zone. Owners of production stations are the vendors. The objective function of the problem of MGs participation in the capacity market is obtained as (1).

$$\begin{aligned}
 & \text{Minimize } \sum_{r=1}^R \sum_{b=1}^B (\pi_{r,b}^{GR} \cdot P_{r,b}^{GR}) - \sum_{l=1}^L \sum_{b=1}^B (\pi_{l,b}^{VRR} \cdot [P_{l,b}^{VRR} - P_{l,b}^{VRR-MG}]) \\
 & + \sum_{l=1}^L \sum_{b=1}^B (\pi_{l,b}^{TU} \cdot P_{l,b}^{TU}) + \sum_{c=1}^C \left[\frac{\sum_{i=1}^{N_s} C_i^l \cdot P_i^{MG}}{Ny \times 365} + \sum_{i=1}^{N_s} C_i^{OM} \cdot P_i^{MG} + \pi_c^{DR} \cdot DR_c^{MG} \right]
 \end{aligned} \tag{1}$$

Where R , L and B are the number of sources, number of variable resource requirements (VRR) and blocks, respectively. $\pi_{r,b}^{GR}$ and $P_{r,b}^{GR}$ are the suggested price and capacity of producer r while $\pi_{l,b}^{VRR}$ and $P_{l,b}^{VRR}$ are the proposed price and capacity of load l in the capacity block b , respectively. π_l^{TU} and P_l^{TU} are the parameters of

new transmission line installation. $P_{l,b}^{VRR-MG}$ is an auxiliary variable that indicate the effect of MG on VRR. DR_c^{MG} is the value of demand response in MG. C_i^I , C_i^{OM} and π_c^{DR} are the cost of new sources, operation cost (excluding fuel) and π_c^{DR} is maintenance of distributed generation resources while the cost of responding to loads in dollars per kilowatt-day, respectively. N_s is the sources of MG and N_y is also the number of planning periods of investment in the MG based on the year [27]. The introduced strategy is implemented on BRA of 2020/2021 PJM capacity market data. One-block offering curves, and for VRR three-block bidding curves are used for production source and demand response. All case studies have been run using CPLEX within general algebraic modeling system (GAMS). To investigate the efficiency of the proposed model, its performance must be evaluated considering various core parameters. In the following, the effects of DR, generation capacity, and CETO on the proposed model are discussed in detail.

3. RESULTS AND DISCUSSION

3.1. Analysis based on the certain number of microgrids in each area (case 1)

The capacity market is solved in the following four modes for the system in question; i) capacity market regardless of MG, ii) capacity market with the maximum of one MG in each area, iii) capacity market by considering the maximum of two MGs in each area, and iv) capacity market with the maximum of three MGs in each area.

Based on the simulation results, in modes 2 to 4, the maximum allowable number of MGs in areas 1, 2 and 10 is considered. The cost of power generation, the cost of transmission network development, the profit of selling capacity to consumers, the cost of MG and finally the cost of capacity market is presented in Table 1. It is clear that the addition of MGs causes a significant reduction in the cost of transmission system development. With the addition of the first MG to each area, the development cost of transmission system will be reduced about \$6 million, while the MG will cost only about \$2 million. Moreover, the addition of MGs causes a slight increase in the profitability of selling capacity to consumers.

Table 1. Capacity market costs with different numbers of MGs in each area (case 1)

| Costs | 0 MG | 1 MG | 2 MGs | 3 MGs |
|----------------------|------------|-------------|-------------|-------------|
| Generation Cost | 44,092,610 | 44,092,610 | 44,092,610 | 44,092,610 |
| VRR Revenue | 99,528,450 | 100,564,200 | 101,052,000 | 101,175,400 |
| Upgrade cost | 89,839,000 | 83,839,000 | 77,839,000 | 71,839,000 |
| MG Cost | 0 | 2,029,315 | 4,058,630 | 6,087,945 |
| Capacity Market Cost | 34,403,160 | 29,396,670 | 2,493,820 | 2,084,414 |

According to Table 1, with the addition of the first MG to each area, the capacity market cost is reduced more than \$5 million, which is significant and equivalent to a reduction of 15% in the capacity market cost for the first case. With the increase in the number of MGs in each area, the process of reducing the cost of transmission development and also the process of reducing the cost of capacity market continues. Finally, the addition of the third MG the cost of line development reduced about 18 million in comparison with the first case, while the cost of capacity market has also condensed by 14 million. The outcomes proved that increasing the number and capacity of MGs in each area result in the eliminating the need for transmission system development and reduce the market cost of capacity. Figure 1 shows the amount of resource power generation for the four modes for each region. Figure 2 also shows the amount of consumer purchased capacity (P^{VRR}).




Figure 1. The amount of sold capacity resources in the capacity market (case 1)

As shown in Figure 2, with increasing the number of MGs, P^{VRR} has also enhanced. Figure 3 shows the extent of transmission network development without MG and with different numbers of MGs. It is indicated that the addition of MGs will gradually decrease the amount of transmission system development.

Based on the simulation results, the values of transmission network development in the four desired modes are 89,839, 8,389, 77,839, and 71,839 MW respectively. Comparing the capacity of the first and second modes shows that addition of one MG to the areas, the amount of capacity which is required to develop the transmission system reduced by 6,000 MW, almost equal to 6.6% reduction in capacity. This amount is significant, then MG can be considered as a suitable alternative for transmission system development. The second mode compared to the third mode and also the third mode compared to the fourth mode had a reduction in transmission capacity of 600 MW. Figure 4 shows the sold capacity of all MGs for all four modes. So, increasing the number of MGs result in the growing of the amount of sold capacity.




Figure 2. The amount of capacity purchased by consumers (case 1)




Figure 3. The amount of transmission network development (case 1)




Figure 4. The amount of sold capacity of MGs in each mode (case 1)

3.2. Analysis for maximum number of microgrids in all areas (case 2)

In the previous simulation, it was assumed that each region would be able to construct a certain number of MGs. A general constraint exists for the second scenario such a way that a maximum number of N_{mg} MGs can be constructed in one or more areas. Four different modes are introduced as being as; i) mode 1: none of the areas have MGs, ii) mode 2: maximum 5 MGs in all areas, iii) mode 3: maximum 10 MGs in all areas, and iv) mode 4: maximum 15 MGs in all areas

The related results of production cost, line investment cost, capacity sales profit, and MG cost are presented in Table 2. Figure 5 shows that the application of MGs did not affect the amount of sold capacity in any areas. Figure 6 displays that increasing the number of MGs will enlarge the amount of profit from capacity. Because, using of MGs reduced the price of capacity. According to Figure 7, by using of MGs the transmission development capacity is reduced. It can be found from Figure 8 that enhancement of the number of MGs lead to growth of sold capacity.

Table 2. Capacity market costs with different numbers of MGs in all areas (case 2)

| Costs | 0 MG | 5 MGs | 10 MGs | 15 MGs |
|----------------------|------------|-------------|-------------|-------------|
| Generation cost | 44,092,610 | 44,092,610 | 44,092,610 | 44,092,610 |
| VRR revenue | 99,528,450 | 101,119,280 | 101,580,010 | 101,938,700 |
| Upgrade cost | 89,839,000 | 79,839,000 | 69,839,000 | 59,839,000 |
| MG cost | 0 | 3,382,191 | 6,764,383 | 10,146,580 |
| Capacity market cost | 34,403,160 | 26,121,020 | 19,115,720 | 12,139,510 |




Figure 5. The amount of sold capacity resources in the capacity market (case 2)




Figure 6. The amount of capacity purchased by consumers (case 2)




Figure 7. The amount of transmission system development (case 2)




Figure 8. The amount of sold capacity of MGs in each mode (case 2)

4. CONCLUSION

Role of MGs as an alternative solution for transmission system development was investigated to inspect if MGs can be introduced as a suitable alternative for transmission line development. A method has been proposed for simulation of MGs in the capacity market as a solution for the problem of transmission system development planning. The capacity market is analyzed in four modes such as no MG, with only one MG in each area, with two MGs in each area, and three MGs involved in each area. The results show that the addition of MGs causes a significant reduction in the cost of transmission system development. By adding of one MG to each area, the cost of system development will be reduced by 6 million dollars, and while the cost of MG will be only 2 million dollars. Increasing the number of MGs caused a slight increase in the profitability of selling capacity to consumers. These results proved that the requirement of power system development will be eliminated using enough numbers of microgrids with a suitable capacity.

ACKNOWLEDGEMENTS

The authors would like to express their gratitude to Islamic Azad University for the facilities provided during this research work.

REFERENCES

- [1] M. Sajjadi, H. Seifi, and H. Delkhosh, "A new approach for system-wide power system frequency model validation via measurement data," *Engineering Reports*, vol. 4, no. 1, Jan. 2022, doi: 10.1002/eng2.12446.
- [2] A. Nochian, O. Mohd Tahir, S. Maulan, and A. R. Mikaeili, "A REVIEW OF SYSTEMATIC APPROACH FOR SUSTAINABLE REDEVELOPMENT OF A CLOSED LANDFILL SITE," *Jurnal Teknologi*, vol. 78, no. 5, Apr. 2016, doi: 10.11113/jt.v78.8318.
- [3] A. Nochian, O. Mohd Tahir, S. Mualan and D. Rui, "Toward Sustainable Development of a Landfill: Landfill to Landscape or Landscape along with Landfill? A Review," *Pertanika Journal of Social Science and Humanities*, vol. 27, no. 2, pp. 949–962, 2019, doi: 10.6084/m9.figshare.9691301.v1.
- [4] M. Asadi *et al.*, "Optimal Placement and Sizing of Capacitor Banks in Harmonic Polluted Distribution Network," in *2021 IEEE Texas Power and Energy Conference (TPEC)*, Feb. 2021, pp. 1–6, doi: 10.1109/TPEC51183.2021.9384992.
- [5] M. Karami, N. Mariun, K. Ab, R. Mohd, and N. Misron, "Analysis of rotor asymmetry fault in three-phase line start permanent magnet synchronous motor," *Facta universitatis - series: Electronics and Energetics*, vol. 34, no. 4, pp. 483–498, 2021, doi: 10.2298/FUEE2104483K.
- [6] Y. Hu, Z. Sun, L. Cao, Y. Zhang, and P. Pan, "Optimization configuration of gas path sensors using a hybrid method based on tabu search artificial bee colony and improved genetic algorithm in turbofan engine," *Aerospace Science and Technology*, vol. 112, p. 106642, May 2021, doi: 10.1016/j.ast.2021.106642.
- [7] A. Sahragard, H. Falaghi, M. Farhadi, A. Mosavi, and A. Estebarsari, "Generation Expansion Planning in the Presence of Wind Power Plants Using a Genetic Algorithm Model," *Electronics*, vol. 9, no. 7, p. 1143, Jul. 2020, doi: 10.3390/electronics9071143.
- [8] E. Karunarathne, J. Pasupuleti, J. Ekanayake, and D. Almeida, "Multi-Leader Particle Swarm Optimization for Optimal Planning of Distributed Generation," in *2020 IEEE Student Conference on Research and Development (SCOREd)*, Sep. 2020, pp. 96–101, doi: 10.1109/SCOREd50371.2020.9250957.
- [9] Z. Abdmouleh, A. Gastli, L. Ben-Brahim, M. Haouari, and N. A. Al-Emadi, "Review of optimization techniques applied for the integration of distributed generation from renewable energy sources," *Renewable Energy*, vol. 113, pp. 266–280, Dec. 2017, doi: 10.1016/j.renene.2017.05.087.
- [10] M. Karami, N. Mariun, M. A. M. Radzi, and G. Varamini, "Intelligent stability margin improvement using series and shunt controllers," *International Journal of Applied Power Engineering (IJAPE)*, vol. 10, no. 4, p. 281, Dec. 2021, doi: 10.11591/ijape.v10.i4.pp281-290.
- [11] K. S. Sambaiah and T. Jayabarathi, "Loss minimization techniques for optimal operation and planning of distribution systems: A review of different methodologies," *International Transactions on Electrical Energy Systems*, vol. 30, no. 2, Feb. 2020, doi: 10.1002/2050-7038.12230.
- [12] R. A. El Sehiemy, F. Selim, B. Bentouati, and M. A. Abido, "A novel multi-objective hybrid particle swarm and salp optimization algorithm for technical-economical-environmental operation in power systems," *Energy*, vol. 193, p. 116817, Feb. 2020, doi: 10.1016/j.energy.2019.116817.
- [13] M. Karami, N. Bin Mariun, M. Z. A. Ab-Kadir, N. Misron, and M. A. Mohd Radzi, "Motor Current Signature Analysis-based Non-invasive Recognition of Mixed Eccentricity Fault in Line Start Permanent Magnet Synchronous Motor," *Electric Power Components and Systems*, vol. 49, no. 1–2, pp. 133–145, Jan. 2021, doi: 10.1080/15325008.2021.1937386.
- [14] T. S. Ustun, C. Ozansoy, and A. Zayegh, "Recent developments in microgrids and example cases around the world—A review," *Renewable and Sustainable Energy Reviews*, vol. 15, no. 8, pp. 4030–4041, Oct. 2011, doi: 10.1016/j.rser.2011.07.033.
- [15] B. Mukhopadhyay and D. Das, "Optimal multi-objective expansion planning of a droop-regulated islanded microgrid," *Energy*, vol. 218, p. 119415, Mar. 2021, doi: 10.1016/j.energy.2020.119415.
- [16] F. Varasteh, M. S. Nazar, A. Heidari, M. Shafie-khah, and J. P. S. Catalão, "Distributed energy resource and network expansion planning of a CCHP based active microgrid considering demand response programs," *Energy*, vol. 172, pp. 79–105, Apr. 2019, doi: 10.1016/j.energy.2019.01.015.
- [17] M. Refaat, S. Aleem, Y. Atia, Z. Ali, and M. Sayed, "Multi-Stage Dynamic Transmission Network Expansion Planning Using LSHADE-SPACMA," *Applied Sciences*, vol. 11, no. 5, p. 2155, Feb. 2021, doi: 10.3390/app11052155.
- [18] J. A. Aguado, S. de la Torre, J. Contreras, A. J. Conejo, and A. Martínez, "Market-driven dynamic transmission expansion planning," *Electric Power Systems Research*, vol. 82, no. 1, pp. 88–94, Jan. 2012, doi: 10.1016/j.epr.2011.09.001.
- [19] D. Pozo, E. E. Sauma, and J. Contreras, "A Three-Level Static MILP Model for Generation and Transmission Expansion Planning," *IEEE Transactions on Power Systems*, vol. 28, no. 1, pp. 202–210, Feb. 2013, doi: 10.1109/TPWRS.2012.2204073.

- [20] J. Lin and B. Vatani, "Impact of capacity market design on power system decarbonization," in *2017 14th International Conference on the European Energy Market (EEM)*, Jun. 2017, pp. 1–6, doi: 10.1109/EEM.2017.7981870.
- [21] D. Hach, C. K. Chyong, and S. Spinler, "Capacity market design options: A dynamic capacity investment model and a GB case study," *European Journal of Operational Research*, vol. 249, no. 2, pp. 691–705, Mar. 2016, doi: 10.1016/j.ejor.2015.08.034.
- [22] S. S and S. K, "DEMAND SIDE MANAGEMENT: DEMAND RESPONSE, INTELLIGENT ENERGY SYSTEMS AND SMART LOADS," *INTERNATIONAL JOURNAL OF ELECTRICAL ENGINEERING & TECHNOLOGY*, vol. 10, no. 1, Jan. 2019, doi: 10.34218/IJEET.10.1.2019.003.
- [23] P. Interconnection, "Retail Electricity Consumer Opportunities for Demand Response in PJM's Wholesale Markets," 2014, [Online]. Available: [http://www.pjm.com/\\$-\\$/media/markets-ops/dsr/end-usecustomer-fact-sheet.ashx](http://www.pjm.com/$-$/media/markets-ops/dsr/end-usecustomer-fact-sheet.ashx).
- [24] M. H. Albadi and E. F. El-Saadany, "A summary of demand response in electricity markets," *Electric Power Systems Research*, vol. 78, no. 11, pp. 1989–1996, Nov. 2008, doi: 10.1016/j.epsr.2008.04.002.
- [25] Ying Xiao, Yen-Yu Lee, F. S. Bresler, J. Bastian, and A. Engle, "Integration of Demand Resource into PJM capacity market incremental auction," in *2013 IEEE Power & Energy Society General Meeting*, 2013, pp. 1–5, doi: 10.1109/PESMG.2013.6673055.
- [26] M. Sajjadi and H. Seifi, "A new Approach for Parameter Estimation of Power System Equipment Models," in *2019 International Power System Conference (PSC)*, Dec. 2019, pp. 530–535, doi: 10.1109/PSC49016.2019.9081543.
- [27] B. Vatani, B. Chowdhury, and J. Lin, "The Role of Demand Response as an Alternative Transmission Expansion Solution in a Capacity Market," *IEEE Transactions on Industry Applications*, vol. 54, no. 2, pp. 1039–1046, Mar. 2018, doi: 10.1109/TIA.2017.2785761.

BIOGRAPHIES OF AUTHORS



Mohammad Khadem    graduated with B.Eng (2011) and M.Sc (2021) in electrical engineering from Islamic Azad University, Iran. Currently, he is a senior electrical and instrumentation engineer at National Iranian South Oil Company (NISOC) in Ahvaz, Iran. His research interests include microgrids, renewable energy, fault detection in electrical machines and artificial intelligence. He can be contacted at email: mohammad.khadem8739@yahoo.com.



Mahdi Karami    received his B.Eng in Electrical and Electronic Engineering from Islamic Azad University (2005), received M.Sc. (2012), and Ph.D. (2015) from Universiti Putra Malaysia (UPM). Currently, he is an Assistant Professor and Head of the Department of Electrical Engineering, Jam Branch, Islamic Azad University. To date he has authored and co-authored of several journals and conference articles, book and book chapter. He also serves as reviewer for Taylor & Francis, IET, and Wiley. Karami's research interests are fault detection in electrical machines, condition monitoring techniques, power system optimization, and artificial intelligence. He can be contacted at email: mehdikarami.en@gmail.com